

Submit Form To:

Amarillo Field Office
ATTN: Assistant Field Manager for Operations
801 S. Fillmore, Suite 500
Amarillo, TX 79101

Cliffside Gas Plant Status Report

Date & Time of Outage: December 17, 2016 at 0015 (CDT)

Cause of Outage: Reboiler went down, several attempts to restart without success. The plant was shut down at 0230 hours due to a frozen reflux line.

Factors Causing Restart:

- Extremely cold weather creating frozen pipes.

Current Status:

- 1535 hours, Monday, December 19, 2016 – Flow of helium to the pipeline commenced at approximately 1300 hours. Current flow is 2000 Mcf per day. Residue is being sold to Kinder Morgan at a rate of approximately 7000 Mcf per day.

Forecast:

- Estimate is that plant will be at full production by 1800 hours, Tuesday, December 20, 2016 barring any unexpected circumstances.

Pipeline Pressure at Cliffside: At 1535 (CDT), Monday, December 19, 2016 = 972 psig

Next Report: 0900 (CDT), Tuesday, December 20, 2016

Points of Contact:

Sam Burton, Acting Field Manager at 806-683-7726, sburton@blm.gov, or
Wesley W. Ingram, Acting AFM-HE Ops at 806-356-1023, wingram@blm.gov